

IMPORTANT PRODUCT INFORMATION

READ THIS INFORMATION FIRST

Products: 6" QuickPanel™ Control IC754CBL06CTD-LG
IC754CSL06CTD-LG
6" QuickPanel View IC754VBL06CTD-LG
IC754VSL06CTD-LG

The color TFT LCDs in the models above have been changed to a new display. Full details below.

Documentation

Hardware User's Guide: GFK-2243E or later

Functional Compatibility

The new LCD display has the same dimensions, resolution, color depth, temperature rating and backlight life as the LCD used in earlier revisions. It is functionally identical to the previous LCD display.

Proficy™ Machine Edition (and earlier CIMPLICITY® Machine Edition) projects for the existing Windows CE™ based QuickPanel View and Control models are compatible with the new models. (See "Operational Notes" below.)

Problems Resolved by this Revision of Product

The supplier of the LCD display used in the previous versions of the products listed above has obsoleted that display and replaced it with the new display.

Operational Notes

CIMPLICITY Machine Edition v4.5, or later versions (or in later revisions, Proficy Machine Edition) is required to configure the QuickPanel View and Control products listed above.

Installation in Hazardous Locations

The following information is for products bearing the UL marking for Hazardous Locations:

WARNING - EXPLOSION HAZARD - SUBSTITUTION OF COMPONENTS MAY IMPAIR SUITABILITY FOR CLASS I, DIV. 2.

WARNING - EXPLOSION HAZARD - WHEN IN HAZARDOUS LOCATIONS, TURN OFF POWER BEFORE REPLACING OR WIRING MODULES.

WARNING - EXPLOSION HAZARD - DO NOT CONNECT OR DISCONNECT EQUIPMENT UNLESS POWER HAS BEEN SWITCHED OFF OR THE AREA IS KNOWN TO BE NONHAZARDOUS.

Power, input and output (I/O) wiring must be in accordance with Class I, Div. 2 wiring methods, Article 501 4(b) of the National Electrical Code, NFPA 70 and in accordance with the authority having jurisdiction.